

K.Dis.No. 7543/E4/2023

**Office of the Deputy Director
of Health Services, Karur-639 007.**

Dated.29.11.2023

Sub: Public Health and Preventive Medicine – **KARUR PUBLIC SCHOOL** -
Sanitary Certificate for the year 2023 – 2024 - issued regarding.

Ref: Application dated. 25.10.2023, KARUR PUBLIC SCHOOL,
154, Sanjay Nagar, Karur – Erode Main Road, Athur Post, Karur
District – 639 008.


((())

With reference to the above, the Sanitary Certificate for
KARUR PUBLIC SCHOOL, 154, Sanjay Nagar, Karur – Erode Main Road,
Athur Post, Karur District – 639 008 is issued for the year 2023 – 2024.

Encl:- Sanitary Certificate for 2023 – 2024

**Deputy Director of Health Services
Karur**

To:
KARUR PUBLIC SCHOOL,
154, Sanjay Nagar,
Karur – Erode Main Road,
Athur Post, Karur District – 639 008.


29/11/2023



GOVERNMENT OF TAMIL NADU
DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
SANITARY CERTIFICATE - YEAR 2023-24


[Under Tamil Nadu educational rules](Appendix-3 and Chapter III Rule:24)

I hereby declare that I have inspected the KARUR PUBLIC SCHOOL, 154, Sanjay Nagar, Karur - Erode Main Road, Athur Post, Karur District - 639 008 building and premises on the day of 25.11.2023 and Certify

- : that the accommodation provided for each of several classes is sufficient for the minimum number of pupils taught there in and is properly ventilated and lighted
- : that is neat and clean;
- : that the building is maintained in substantial repair;
- : that the latrine arrangement are adequate and satisfactory;
- that the supply of drinking water is wholesome; and
- : that in all necessary respects the sanitation is good.

This Certificate is issued subject to the following conditions

1. The garbage generated within the school premises should be collected and disposed off properly by appointing required sanitary staff.
2. On any account the garbage should not be burnt.
3. The Students should be educated to prevent the usage of plastics and no one should bring the plastic carry bags, use and throw tumblers to the Institute.
4. Fire precaution measures and First Aid Box should be provided.
5. Child Labour should not be engaged in any account.
6. This Certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintenance of sanitation, building and toilets in the school.
7. SOP for Covid 19 should be followed in your Campus.
8. This Sanitary Certificate is valid for One Educational Year.


Block Health Supervisor,
Uppidamangalam.

R.No: 7543/E4 /2023 Dated: 29.11.2023



Counter Signed


DEPUTY DIRECTOR
Of Health Services, KARUR.

29/11/2023



-: TEST WATER BEFORE TASTE :-

TAMIL NADU WATER SUPPLY & DRAINAGE BOARD
DISTRICT LEVEL WATER TESTING LABORATORY

TWAD Board, No 116/1, Bala Arcade, Poonga Nagar, Dindigul Main Road, Thanthonimalai, Karur-639005

TEST REPORT

| | |
|---|---|
| From Thiru.K.S.Velmurugan B.Sc., Junior Water Analyst TWAD Board, DWT Lab A/C Karur | To Karur Public School 154, Sanjay Nagar Karur - Erode Main Road Athur (Po), Karur - 639008 |
|---|---|

Lr.No: 37757/JWA/TWAD Lab/KRR/2023/Dated: 02.04.2024


Sir,
Sub: Examination of water sample - Report furnished - Reg.
1) T.O Invoice No. 5576/dt 26.03.2024 for Rs1652 /-
2) DD.No :269773/ dt 26.03.2024 Rs 1652/-UCO Bank, Karur

The results of analysis for the water sample sent under reference is furnished below.

| | |
|----------------------|-----------------------------|
| Sample No | 37757 |
| Date of Collection | 26.03.2024 |
| Date of Receipt | 26.03.2024 |
| Panchayat | PVT |
| Source | RO Water |
| Location of Sampling | Sanjay Nagar, School Campus |
| Habitation | Sanjay Nagar |
| Panchayat | Andankoil East |
| Union | Thanthoni |
| Collected by | Customer |

| BIS 10500 : 2012 | Acceptable limit | Permissible limit in the absence of alternate source | Result for Water sample No: |
|---|------------------|--|-----------------------------|
| I PHYSICAL EXAMINATION | | | 37757 |
| 1 Appearance | -- | -- | Clear |
| 2 Colour (Pt.Co - scale) | 5 | 15 | Colourless |
| 3 Odour | Agreeable | 0 | None |
| 4 Turbidity NT units | 1 | 5 | 0 |
| 5 Total dissolved solids, mg/L | 500 | 2000 | 135 |
| 6 Electrical conductivity micro mho/cm | -- | -- | 193 |
| II CHEMICAL EXAMINATION | | | |
| 7 pH | 6.5 to 8.5 | 6.5 to 8.5 | 7.01 |
| 8 Ph-Alkalinity as CaCO ₃ mg/L | | | 0 |
| 9 Total Alkalinity CaCO ₃ mg/L | 200 | 600 | 44 |
| 10 Total Hardness as CaCO ₃ mg/L | 200 | 600 | 61 |
| 11 Calcium as Ca mg/L | 75 | 200 | 7 |
| 12 Magnesium as Mg mg/L | 30 | 100 | 10 |
| 13 Iron as Fe mg/L | 0.3 | 1.0 | 0.00 |
| 14 Free Ammonia as NH ₃ mg/L | 0.5 | 0.5 | 0.00 |
| 15 Nitrate as NO ₃ mg/L | 45 | 45 | 0 |
| 16 Chloride as Cl mg/L | 250 | 1000 | 27 |
| 17 Fluoride as F mg/L | 1 | 1.5 | 0.0 |
| 18 Sulphate as SO ₄ mg/L | 200 | 400 | 0 |
| 19 Phosphate as PO ₄ mg/L | -- | -- | 0.00 |
| 20 Free residual chlorine mg/L | 0.2 | 1.0 | 0 |
| III BACTERIOLOGICAL EXAMINATION | | | |
| 1 Fecal coliform (colonies per 100 ml) | 0 | 0 | 0 |

REPORT: 37757 The water is *Physically, Chemically Potable and Bacteriologically Not Contaminated* with Respect to the Tested Parameters.


27/4/2024
Junior Water Analyst
TWAD Board, DWT Lab
Karur